



Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1292	22-Feb-2000	Number 18	Issue date 8-Apr-2024	30-Apr-2025

Page 1 of 3

Product designation

Pertronic, Model F100A, fire indicator panel

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Pertronic Industries Pty Limited
Unit B2, Hallmarc Business Park, 2A Westall Road, SPRINGVALE, VIC, AUSTRALIA, 3171

Registrant

Pertronic Industries Pty Limited
Unit B2, Hallmarc Business Park, 2A Westall Road, SPRINGVALE, VIC, AUSTRALIA, 3171

Producer

Pertronic Industries Limited
17 Eastern Hutt Road, WINGATE, LOWER HUTT, NEW ZEALAND, 5019

Conformance criteria and evaluation

The Pertronic, Model F100A, fire indicator panel has been evaluated and verified as conforming with the relevant requirements of the following criteria.

1. Australian Standard AS 4428.1-1998, 'Fire detection, warning, control and intercom systems - Control and indicating equipment - Fire'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

- i. Compatibility of this equipment with new or existing actuating devices should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh
Executive Officer – ActivFire Scheme



Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1292	22-Feb-2000	Number 18	Issue date 8-Apr-2024	30-Apr-2025

Producer's description

The Pertronic, Model F100A, fire indicator panel is an analogue addressable automatic fire alarm system that communicates with detector zones and control modules via a 2-wire fault tolerant loop. Each loop is designed to accommodate up to 198 addressable devices, allowing a maximum of 99 sensors and 99 monitor/control modules.

The Firetronix, Model F100A Loop Responder and Relay Responder allow for conventional detector circuits and relay outputs to be used on the loop. The F100A Loop Responder provides for 8 conventional detector circuits and one relay output, with a maximum of 11 Loop Responders on each loop. The F100A Relay Responder provides 4 relay outputs that may be monitored with a maximum of 24 Loop Responders on each loop. The loop relays may be configured as warning system relays, ACF relays, or as door holder relays. The Pertronic, Model F100A, fire indicator panel provides seven relay outputs; three monitored for warning system, four relays for Master Alarm, Fault, Battery Fail, and Door Holder.

The Pertronic, Model F100A, fire indicator panel annunciates all point information on a back-lit, 2 line by 40 character liquid crystal display (LCD). The seven push buttons within the Fire Fighters Facility (FFC) are designated External Bells Isolate, Warning System Isolate, Acknowledge, Reset, Isolate, Previous, and Next. Three control buttons adjacent to the FFC are designated Bell On, ACF Isolate, and Door Handle Isolate. User access to the FIP is provided by six dynamic buttons below the LCD.

Technical specification

The following details are a representative extract of the technical specification for the Pertronic, Model F100A, fire indicator panel and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Power Supply:

Type:	Switch Model 22864
Nominal output voltage:	27.4 V
Maximum rated output current:	1.53 A
Circuit current limit:	1.8 A
Current limit rating:	1.8 A (electronic)

Battery charger:

Voltage setting:	27.4 V
Maximum rated output:	1.53 A
Current limit device rating:	10 A (fuse)

Panel:

Quiescent panel load:	0.31 A @ 27.3 V
Minimum power supply load:	0.526 A
Required battery capacity:	7.66 Ah
Nominated battery capacity:	15 Ah

Supplementary information

Evaluated modules

Module description	Assembly number	Rev	PCB number	Iss	Tech. drawing number	Iss
F100A main PCB	F100 A1-A1	1.1	F100 A1-A1	1.3	F100 A1-A1	1.3.6
F100a 1.5a power supply	F100 A-A3		F100 A-A3	2.0	F100 A-A3	2.3
F100A keyboard display unit	F100 A-A2		F100 A-A2	1.5	F100 A-A2	2.0
F100A LCD remote mimic	F100 A-2		F100 A-2	1.5	F100 A-2	2.0
Firetronix 8 circuit, 1 relay loop responder	AA8LR	1.0	AA8LR	2.11.a	AA8LR	2.11.2
Firetronix 4 way relay loop responder (monitored)	AA4MMR	1.0	AA4MMR	2.11	AA4MMR	2.11.1
Firetronix 4 way relay loop responder (not monitored)	AA4NRR	1.0	AA4NRR	1.0	AA4NRR	1.1

Schedule to Certificate of Conformity

Certificate num.	Registration date	Version	Valid until	
afp - 1292	22-Feb-2000	Number 18	Issue date 8-Apr-2024	30-Apr-2025

EPROMS:

Firmware F100A02	Version 1.62.1
Firmware LCD	Version 3.06

Addressable devices:

Device type	Max addressable points on analogue loop	Max addressable points on analogue line	Reference
System Sensor, M500MB Monitor Module	99	40*	XF1456/R2, Feb 2000, AS 4428.1- 1998
System Sensor, M501MB Monitor Module (miniature)	99	40*	"
System Sensor, M503ME Monitor Module (micro with LED)	99	40*	"
System Sensor, M500CH Control Module	99	40*	"
System Sensor, M500X Zone Isolator	99	40*	"
Firetronix AA8LR S Circuit, 1 Relay Loop Responder	11	n/a	"
Firetronix, AA4MRR 4 Way Relay Responder	24	n/a	"

Actuating devices

AZF module num.: Pertronic loop protocol

Nominal detector line voltage: 17 V

Device type	Max addressable points on analogue loop	Maximum addressable points on analogue line	Reference
System Sensor, 1251AUS, Smoke Ionisation	99	40*	XF1456/R2, Feb 2000, AS 4428.1- 1998
System Sensor, 2251AUS, Smoke Photoelectric	99	40*	"
System Sensor, 3251AUS, Sensor	99	40*	"
The above detectors with the System Sensor B501 base.			
System Sensor, M500KAC, MCP	99	40*	XF1456/R2, Feb 2000, AS 4428.1- 1998

AZF module num.: Responder Module Rev. 1:

Device type	Maximum number of devices per AZF	Reference
System Sensor, 51A51, Heat Type A	40*	XF1742/R1, Dec 2000,
System Sensor, 51C51, Heat Type C	40*	Compatibility Assessment
The above detectors with the System Sensor B401 base.		

* Maximum number of detectors per AZF/AZC allowed by code.