



CSIRO Verification Services Clayton, Victoria, Australia +61 13 0036 3400 https://activfire.csiro.au

Certificate of Conformity

Certificate num.	Registration date	V	ersion	Valid until	
afp - 3384	30-Jul-2019	Number 7	Issue date 3-Apr-2024	30-Apr-2025	Page 1 of 3

Product designation

System Sensor, Model 2251BPI-IV/2251BPI-W/2251BPI-BK, adjustable sensitivity, photoelectric smoke detector

(Refer to the Schedule/enclosures for further specified details)

Agent/distributor

Pertronic Industries Pty Limited

Unit B2, Hallmarc Business Park, 2A Westall Road, SPRINGVALE, VIC, AUSTRALIA, 3171

Registrant

Honeywell Security and Fire 9 Columbia Way, BAULKHAM HILLS, NSW, AUSTRALIA, 2153

Producer

Xi'an System Sensor Electronics, Ltd

28 Tuan Jie South Road, Xi'an Hi-tech Development Zone, XI'AN, SHAANXI, CHINA, 710075

Conformance criteria and evaluation

The System Sensor, Model 2251BPI-IV/2251BPI-W/2251BPI-BK, adjustable sensitivity, photoelectric smoke detector has been evaluated and verified as conforming with the relevant requirements of the following criteria.

 Australian Standard AS 7240.7:2018, 'Fire detection and alarm systems - Part 7: Point-type smoke detectors using scattered light, transmitted light or ionization (ISO 7240-7:2018, MOD)'.

Limitations/conditions of conformance

Limitations/conditions of conformance, where identified on this certificate, are derived from qualifications from evaluation(s) for conformity and/or other related technical documentation. All details with respect to design, assembly and installation instructions and restrictions should be checked against the producer's current technical manual/data sheets and the requirements of the Authority having Jurisdiction.

Specified limitations/conditions, determined from the evaluation for conformity, include the following.

i. Compatibility of this fire detector and its base assembly with new or existing control and indicating equipment should be verified prior to installation.

This certification is issued within the scope of CSIRO Verification Services – Rules governing ActivFire Scheme and is valid only for the product(s) as submitted for evaluation and verification of conformity, subject to the following conditions.

- Reference to details, limitations and requirements, where documented as a schedule/enclosure with this certificate.
- The Registrant is responsible for their attestation of conformity and ensuring that on-going production complies with the conformance criteria defined in this certificate.
- This certificate will not be valid if any changes or modifications are made to the product which have not been notified and validated by CSIRO Verification Services.
- This certificate is subject to periodical re-validation upon verification that all requirements, as determined by the conformity assessment body, continue to be satisfactorily met by the Registrant.
- This certificate may only be reproduced in its published form, without modification and inclusive of all schedules/enclosures.
- Any changes, errors or omissions, must be submitted in writing and if necessary or requested, substantiated with relevant evidence.
- Any representations, such as advertising or other marketing related activities or articles shall reflect the correct contents of this certificate and conform with all relevant trade practices .and consumer protection legislation and regulations.
- Any terms or conditions of use as applicable to content and documentation as published or accessed through web sites administered by the CSIRO Verification Services.

Issued by

Kaj Loh Executive Officer – ActivFire Scheme





© CSIRO Australia, 2024

This certificate remains the property of CSIRO and may be subject to amendment, suspension or withdrawal at any time. The validity and authenticity of this certificate can be verified by the certification register located at <u>https://activfire.csiro.au</u>

Schedule to Certificate of Conformity

Certificate num.	Registration date	Ve	ersion	Valid until	
afp - 3384	30-Jul-2019	Number 7	Issue date 3-Apr-2024	30-Apr-2025	Page 2 of 3

Producer's description

The System Sensor, Model 2251BPI-IV/2251BPI-W/2251BPI-BK, adjustable sensitivity, photoelectric smoke detector is a plugin type smoke sensor that combine a photoelectronic sensing chamber with addressable-analog communications. The sensor transmits an analog representation of smoke density over a communication line to a control panel. Rotary decade switches are provided for setting the sensor's address. A drift compensation function has been provided.

Technical specification

The following details are a representative extract of the technical specification for the System Sensor, Model 2251BPI-IV/2251BPI-W/2251BPI-BK, adjustable sensitivity, photoelectric smoke detector and may be subject to change. Complete and current details should be determined from the designated producer's technical manual/data sheets.

Schedule of variant designations

The following is a schedule of validated variant designations of the certified/listed equipment.

Variant			
Туре	Ident.	Colour	Description
	2251BPI-IV	Ivory	adjustable consitivity, photoslastric smalla detector
Model 2251BPI-W White		adjustable sensitivity, photoelectric smoke detector	
	2251BPI-BK	Black	

Schedule of components and/or assemblies

The following is a schedule of validated components and/or assemblies of the certified/listed equipment.

Validated base designation	Colour	Description Base + detector circuit type		Protocol	
System Sensor, Model B501AUS-IV Ivory					
System Sensor, Model B501AUS-W	White	flangeless base	addressable/analog	Flash-Scan™ or	
System Sensor, Model B501AUS-BK	Black				
System Sensor, Model B501BI-IV	lvory			CLIP (Classic Loop Interface Protocol)	
System Sensor, Model B501BI-W	White	short-circuit isolator base			

Schedule of properties/characteristics

The following schedule is an extract of physical and operational properties/characteristics of the certified/listed equipment.

Operating voltage range:	15 to 32 Vdc
Standby current:	360 μA @ 24 Vdc (one communication every 5 seconds with LED blink enabled)
Maximum alarm current (LED on):	6.5 mA @ 24 Vdc
Operating humidity range:	5% to 96% relative humidity, non-condensing
Operating temperature range:	-10°C to 55°C
Height:	2.0" (51 mm)
Diameter:	104 mm (4.1") installed in B501AUS-IV(W/IV/BK) base; 104 mm (4.1") installed in B501BI-IV(W/IV) isolator base
Weight:	147 g (5.2 oz.)
Smoke sensitivity band:	1 and 2
Software version:	A

Schedule to Certificate of Conformity

Certificate num.	Registration date	V	ersion	Valid until	
afp - 3384	30-Jul-2019	Number 7	Issue date 3-Apr-2024	30-Apr-2025	Page 3 of 3

Supplementary information

Schedule of relevant articles

The following schedule is an extract of articles significant and/or related as evidence of conformity.

Reference Ident.			Date issued	Source	
		Title / description	(or date validated)		
Report	XF3261/R6	Evaluation for Conformity of the System Sensor, Model 2251TMBPI-IV/-W combined smoke/heat detector, Model 2251BPI-IV/-W photoelectric smoke detector, Model 5251BPI-IV/-W Class A2 heat detector, and Model 5251RBPI-IV/-W Class A2R heat detector to the requirements of AS ISO 7240.5:2018 and AS 7240.7:2018	30-Jul-2019	CSIRO Fire Systems Laboratory, AU	
Record	XL2037.16/E1	Abridged conformance evaluation record AS 7240.7:2018, Clauses 7 and 8. System Sensor, 2251BPI-BK variant (afp – 3384)	9-Jul-2021	CSIRO, Verification Services, AU	
Instructions	156-6938-000 Ver. A	PERTRONIC INSTALLATION AND MAINTENANCE INSTRUCTIONS 2251BPI-W(smoke) and 2251TMBPI-W(smoke and heat) Intelligent Photoelectric Scattered Light Smoke Sensors	1-Jul-2019	Pertronic Industries Limited, AU	
Instructions	156-6927-000 Ver. C	PERTRONIC INSTALLATION AND MAINTENANCE INSTRUCTIONS 2251BPI-IV (smoke),2251BPI-BK(smoke) and 2251TMBPI-IV Intelligent Photoelectric Scattered Light Smoke Sensors ("156-6927-000_C.doc")	2-Jul-2021		